

No. F6/DFS/MS/WZ/School/2025/ 794

Dated:- 17/06/2025

FIRE SAFETY CERTIFICATE

Certified that the St. Kabir Modern School, Located at Uday Vihar, Part-III, Nilothi, Delhi-110041, running in one block comprised of Ground + 01 Upper Floor only in a building is comprised of 02 blocks – ground + 01 upper floors, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/WZ/2022/470 dated 28/04/2022. The said premise was re-inspected by the officer concerned of this department on 27/05/2025 in the presence of Ms. Jaspreet Kaur (Principal) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17/01/2005 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 17/06/2025 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 17/06/2025 at New Delhi by

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, St. Kabir Modern School, Uday Vihar Part-III, Nilothi, Delhi-110041.

Conditions for validity of fire safety certificate :-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.